

T-Style steel fence post 4' above grade (painted blue).

Property Line

Grade

15'

12"

1. 7' Minimum cover required over top of water main.
2. Install 1" corporation, curb stop and stand with 1" copper pig tail to 24" above grade.
3. All joints in the water lateral stub shall be restrained to the TEE.
4. Tap corporation stop at 2/3 pipe dia. in the plug

Resilient Seated Valve
ANSI/AWWA C515
Waterous AFC 2500 All
D.I. or Approved Equal.

Provide Conductivity
Strap (typ.). Minimum
1/16"x3/4" Wide
Flat Copper Strip.

3'-5'
SPOOL

4"x4" Marker

Cl. 52 DIP

Corporation Stop



Bonestroo

STANDARD DETAILS
DIP SERVICE OR DEAD END LINE



City of
Cottage Grove
Minnesota

Last Revision:
June 2005

COTTAGE GROVE, MINNESOTA

City Plate No.
WAT-8